


- A. TWO LAYERS OF 12.5mm PLASTERBOARD CARRIED UP TO UNDERSIDE OF FLOOR/ROOF.
- B. ONE LAYER OF 15mm FIRELINE BOARD ON 19mm WBP PLY CARRIED UP TO UNDERSIDE OF FLOOR/ROOF.
- C. ONE LAYER OF 12.5mm PLASTERBOARD ON 19mm WBP PLY CARRIED UP TO UNDERSIDE OF FLOOR/ROOF.
- D. ONE LAYER OF 12.5mm PLASTERBOARD ON 19mm WBP PLY TO 2700mm HIGH.
- E. ONE LAYER OF 12.5mm PLASTERBOARD UP TO 2800mm HIGH IN RESTAURANT ONLY.

ALL STUDS BY "GYPROC" LAID IN STRICT ACCORDANCE WITH MANUFACTURE'S INSTRUCTIONS.  
 70mm STDS AT 400mm CENTRE TO CENTRE THROUGHOUT, BUILT UP TO UNDERSIDE OF ROOF.  
 LAY DPC UNDER SOLE PLATE ON CONCRETE FLOOR.  
 LINE ALL DOORS WITH 38mm TREATED TIMBER GROUNDS.  
 SEAL ALL PARTITIONS TO UNDERSIDE OF ROOF/FLOOR AND AROUND DUCTS, PIPES, TRUNKING ETC. TO ENSURE CONTINUITY OF FIRE ENCLOSURE.  
 WHERE PLASTERBOARD IS OMITTED TO ONE FACE OF PARTITION (IE. IN DUCTS), CHANGE STUD TO 'I' SECTION AND BRACE AS REQUIRED.  
 ALL PLASTERBOARD TO BE MOISTURE RESISTANT THROUGHOUT.



AMENDMENTS	
Letter and Date	Description
A 12/5/98	LAYOUT REVISED
B 18/5/98	LAYOUT REVISED
C 26/5/98	DUCT RELOCATED. BOILER MOVED TO ROOF. FIRE SAFETY CERTIFICATE APPLICATION
D 10/6/98	GENERAL AMENDMENTS.
E 23/6/98	DOORS DF22 & DF23 ADDED. TENDER INFORMATION ADDED.
F 25/9/98	SETTING OUT DIMENSIONS ADDED. DOOR VISION PANELS WIDENED TO 200.
G 30/9/98	CHILLER DEPTH REDUCED TO 2000 DF22 (TD HOIST) OMITTED. NEW DF22 TO REVISED W&A&M W/C DUCT. REVISED MALE CREW W.C.
H 20/10/98	RUBBING STRAKES AND S.S ANGLES ADDED TO BACKUP CORRIDOR SHOWN.
J 12/11/98	VERTICAL PARTITION ADDED HANDRAIL & GUARDING TO PUBLIC STAIRS AMENDED.



A

Drawn For:

Approved By:

Site Address:

Site No:

FIRST FLOOR PLAN

Drawing Number	Scale	Drawn By	Date
	1:50		